NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

KLAM 1014

WATER WELL REPORT

STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
DEC 17 1976
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 34S/8E-21CC

State Permit No.

(1) OWNER:

Name John Inman

Address

Chiloquin Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 21 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used —

Size of perforations — in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name —

Type — Model No.

Diam. — Slot size — Set from — ft. to ft.

Diam. — Slot size — Set from — ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 60 gal./min. with 100 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite

Well sealed from land surface to 21 ft.

Diameter of well bore to bottom of seal 9 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal None sacks

How was cement grout placed? —

Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? — depth of strata —

Method of sealing strata off —

Was well gravel packed? ☐ Yes ☒ No Size of gravel: —

Gravel placed from — ft. to — ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number 1

SW ¼ SW ¼ Section 21 T. 34S R. 8E W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 50 ft.

Static level 07 ft. below land surface. Date 10-27-76

Artesian pressure — lbs. per square inch. Date —

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 118 ft. Depth of completed well 118 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
HARd Brown Clay	1	15	
Blue Clay	15	118	50'

Work started 10-26 1976 Completed 10-27 1976

Date well drilling machine moved off of well 10-27- 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Norm Sevey (Drilling Machine Operator) Date 12-1-, 1976

Drilling Machine Operator's License No. 198

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Norm Sevey Well Drilling (Person, firm or corporation) (Type or print)

Address 5619 Leland Dr. K.F. Ore.

[Signed] Norm Sevey (Water Well Contractor)

Contractor's License No. 408 Date 12-1- 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119